



Cognizant Technology Solutions India Private Limited
Cochin Naveda Campus,
Infopark SEZ Phase - II, Brahmapuram P.O
Cochin- 682 303
Kerala, India
CIN- U72300TN1994PTC026590
Tel: +91 - 484 - 4452000
Fax: + 91 - 484 - 4452060
Email: cognizantindia@cognizant.com
Website: www.cognizant.com
23.06.2017

Ref: EHS/KOC/CNC/ECR/13
To,

Ministry of Env., Forest and Climate Change
Regional Office (SZ), Kendriya Sadan, 4th Floor, E&F
Wings, 17th Main Road, Koramangala II Block, Bangalore - 560034

Dear Sir,

Sub: submission of half yearly environmental clearance conditions compliance report for our premises


Ref: Letter No. 85/SEIAA/KL/326/2013 dated 12.12.2013.

With reference to the above EC No, we are hereby submitting our environmental clearance conditions compliance report for our premises Cognizant Technology Solutions Private limited, Info Park Phase 2, Bhramapuram having unit at Survey No: 84, 86, 90, 91, 98 & 144 for the period of 1st Dec 2016 to May 31st 2017.

We kindly request you to acknowledge the receipt of this compliance report.

Thanking You,
Yours Faithfully,

For Cognizant Technology Solutions India Pvt. Limited.


T. Vijaya Kumar,
Sr. Manager.

Encl:

1. Environmental clearance conditions compliance report.

TO WHOMSOEVER IT MAY CONCERN

Requirement: Submission of half yearly environmental clearance conditions compliance report for our premises for the period of July 2016 to Dec 2016

SL.No	Operation Phase	Compliance Description
1	The original width of the Kadamparayar as per cadastral map should be restored and maintained for free flow of flood water.	The canal Kadamparayar are maintained with free flow of water.
2	10 m buffer set back from the edge of the Kadamparayar river on either side should be left as buffer zone and planted with native species.	Buffer zone available and planted native species
3	Underground floor should be avoided to prevent inundation.	No working floor available underground
4	CSR should be specifically for improving the career prospects of local with skilled, semi-skilled and un-skilled capabilities and amount should be earmarked for the same as per the provisions of Companies Bill, 2011.	Career prospects for local skilled, semi-skilled and un-skilled deployed as per the provisions of companies bill,2011
5	The strip of land between the road and the boundary of project site at its south also SW corner should only be used for landscaping including planting of trees.	Used for landscaping and trees planted
6	The level of structures, approach road and open parking must be above the maximum flood level.	Parking are above flood level.
7	The company should provide energy efficient public transport.	Available.
8	Enhance the RWH capacity to at least as specified in KMBR.	RWH provided as specified in KMBR
9	E- Waste management procedures should be adopted as per relevant rules.	Adopted as per rules
10	ETP and solid waste management should be made as per KSPCB.	ETP installed as per KSPCB Norms. Non bio-degradable solid wastes disposed through authorized recyclers.

11	Rain water Harvesting capacity should be installed as per the prevailing provisions of KMBR/KPBR, unless specified elsewhere.	Rain water harvesting system installed as per KMBR
12	Environment Monitoring Cell as agreed under the affidavit filed by the proponent should be formed and made functional.	Environment monitoring cell available as part of facility management services.
13	Suitable avenue trees should be planted along either side of the tarred road and open parking areas, if any, inclusive of approach road and internal roads.	Plants and trees are planted on both sides of internal roads.
14	The project shall incorporate devices for solar energy generation and utilization to the maximum possible extent with possibility of contributing to the national grid in future.	Solar energy light post installed in common drive ways, gardens, solar water heating system installed in cafeteria roof top and Solar energy panel installed with capacity of 10 KWH connected to power grid.
15	Safety measures should be implemented as per the Fire and Safety Regulations.	Fire NOC renewed every year and firefighting equipment's maintained in healthy and operational condition.
16	STP should be installed and functional as per the KSPCB guidelines including that for solid waste management.	STP installed and in operation as per the guidelines. Treated water were used for landscaping purpose.
17	The conditions specified in the Companies ACT, 2013 should be observed for Corporate Social Responsibility.	Separate CSR function available.
18	The Proponent should plant trees at least 5 times of the loss that has been occurred while clearing for the project.	5 times Plants and trees are planted across the facility.
19	Consent from KSPCB under Water and Air acts should have been obtained before initiating the activity.	Integrated consent PCB/HO/EKM/ICO/49/2014 obtained before initiating the activity.
20	All other statutory clearances should have obtained, as applicable, by project proponents from the respective competent authorities including that for blasting and storage of explosives.	All statutory clearance obtained as applicable for the project
21	In case of any change(s) in scope of the project, the project would require a fresh appraisal by this Authority.	Information noted

22	<p>The Authority reserves the right to add additional safeguard measure subsequently, if found necessary, and to take action including revoking of the environment clearance under the provisions of the Environment (Protection) act, 1986, to ensure effective implementation of the suggested safeguard measures in time bound and satisfactory manner.</p>	Information noted
23	<p>The stipulations by Statutory Authorities under different Acts and Notifications should be complied with, including the provisions of Water (Prevention and Control of Pollution) Act, 1986, The Public liability (Insurance) Act, 1991 and EIA Notification, 2006.</p>	The stipulations by Statutory Authorities under different Acts and Notifications will be complied by.
24	<p>The Project proponent should advertise in at least two local newspapers widely circulated in the region, one of which shall be in the vernacular language informing that the project has been accorded environmental clearance and copies of clearance letters are available with the department of Environment and climate change, Govt. of Kerala and may also be seen on the website of the authority at www.seiaakerala.org. The advertisement should be made within 10days from the date of receipt of the clearance letter and a copy of the same signed in all pages should be forwarded to the office of this authority as confirmation</p>	<p>Advertisement made</p> <p>English – Hindu Kochi Date: 24.12.2013</p> <p>Malayalam- Mathrabhumi Date : 24.12.2013</p>
25	<p>A copy of clearance letter shall be sent by the proponent to concerned Grama Panchayat/District panchayat/municipality/Corporation/Urban Local Body and also to the Local NGO, if any, from whom suggestions/representations, if any, were received while processing the proposal. The Environmental Clearance shall also be put on the website of the company by the proponent.</p>	<p>Letter submitted to district office</p> <p>Date: 24.12.2013</p>

